WEST BENGAL ELECTRICITY REGULATORY COMMISSION WEST BENGAL

Petition No. OA-362/20-21

Date of hearing: 23rd September, 2021

Time of hearing: 14.30 hours

Quorum:

Shri Sutirtha Bhattacharya, Chairperson Shri Durgadas Goswami, Member Shri Pulak Kumar Tewari, Member

In the matter of

Application for removal of difficulties in achieving the normative Station Heat Rate allowed by the Hon'ble Commission for Sagardighi Thermal Power Project, Stage-II of 1000 MW (2X500 MW) capacity in term of regulation 8.10 of the West Bengal Electricity Regulatory Commission (Terms and Conditions of Tariff) Regulations, 2011 as amended time to time.

And

In the matter of

The West Bengal Power Development Corporation Limited
Bidyut Unnayan Bhaban
3/C, LA-Block, Sector-III
Salt Lake
Kolkata 700 106. Petitioner

Representatives attended:

The West Bengal Power Development Corporation Limited [Petitioner]

- 1. Sri Sakya Singha Chaudhuri, Advocate,
- 2. Ms. Astha Sharma, Advocate,
- 3. Sri Swapan Kumar Maity, Executive Director (FM & RA)

CASE IN BRIEF

- 1. The West Bengal Power Development Corporation Limited (in short 'WBPDCL') has submitted a petition dated 8th February, 2021 in terms of regulation 8.10 of the West Bengal Electricity Regulatory Commission (Terms and Conditions of Tariff) Regulations, 2011, as amended ("Tariff Regulations") for removal of difficulties in achieving the target station heat rate allowed by the Commission in its tariff order dated 07.07.2017 in respect of Sagardighi generating station, Stage II of 1000 MW (2X500 MW) capacity of WBPDCL. Subsequently, WBPDCL has submitted a supplementary petition dated 17th March, 2021 in continuation of the earlier petition dated 8th February, 2021.
- Upon receipt of the petition and supplementary petition, the Commission has decided to hear WBPDCL and an e-hearing was fixed on 17th August, 2021 at 14.30 hours for which notice dated 23/26.07.2021 was issued.
- 3. In the meantime, WBPDCL also made an additional submission vide dated 16th August, 2021 in supplemental to and in addition to the contents and submissions in the petition and the supplementary petition mentioned hereinabove and requested the Commission to postpone the hearing scheduled. Accordingly, the hearing was rescheduled on 23rd September, 2021. Before the date of hearing, WBPDCL submitted a further additional submission vide dated 8th September, 2021.
- 4. The hearing was held as scheduled where the representatives from WBPDCL were present.

SUBMISSION DURING HEARING

- 4.1 At the outset, before proceeding into the merit of the case, the Advocate-on-Record of WBPDCL submitted that submission of form-3 in terms of regulation 2.10.7 of the WBERC (Conduct of Business) Regulations, 2013 by the Advocates for attending hearing may, perhaps, not be necessary since Vokalatnama in favour of the advocate, in question, is being issued by the petitioner. The Commission has taken a note of it, and shall make necessary amendment in this regard.
- 4.2 Ld Advocate, Shri S. S. Chaudhuri narrated the case of WBPDCL before the Commission. In his submission Shri Chaudhuri inter-alia submitted that, in terms of

paragraph A1 of Schedule 9D of the Tariff Regulations Gross Station Heat Rate (GSHR) of new thermal generating station is required to be computed by multiplying 1.065 with the design heat rate. Shri Chaudhuri submitted that, during amendment of the Tariff Regulations 2013, the Commission has specified the GSHR of Sagardighi Thermal Power Project -phase-II (units III & IV) of WBPDCL as 2276 kCal/kWh where the multiplying factor 1.065 has not been considered, which may be due to some inadvertent error. It is submitted that, construction of Sagardighi Thermal Plant was followed by 2 stage investment approval of the Commission, where it was intimated that, WBPDCL received single bid from BHEL with design heat rate of 2322 kCal/kWh and the same was considered by the Commission. After settlement of the coal issues, performance guarantee test of Sagardighi phase-II (unit III & IV) were conducted and SHR as per PG test comes to 2285 kCal/kWh. Accordingly, Shri Chaudhuri prayed before the Commission to allow GSHR of Sagardighi phase-II (unit III & IV) as 2433 kCal/kWh (by applying multiplication factor of 1.065 over the PG test value) in terms of regulation 2.8.1.4.9 of the Tariff Regulations with retrospective effect through a corrigendum to Tariff Regulations (Amendment) 2013. Shri Chaudhuri in his argument mentioned that, norms specified in paragraph A of Schedule-9A are recommended norms. However, the Commission has to determine the norms of operating parameters under regulation 2.8.1.4.9 of the Tariff Regulations on the basis of design performance parameters.

The learned Advocate, in conclusion, observed that, for curing the deficiency as stated above, amendment to the existing tariff regulations might not be required. He suggested that a corrigendum issued by the Commission might serve the purpose.

OBSERVATIONS OF THE COMMISSION

5. Based on the submission made by the Ld. Advocate of WBPDCL during the hearing, the Commission observed that there seemed to be some merit on the issue raised by WBPDCL. However, the Commission observes that the prayers made by the Petitioner in the Principal Petition and the Supplementary Petitions before the Commission are at variance with each other. As such, the Petitioner is required to submit a fresh amended Petition.

6. The Commission directed the petitioner to submit their arguments in writing on the

above-mentioned issue.

7. The Commission intends to examine the issue raised by WBPDCL in details upon

receipt of the amended Petition and the written submission by WBPDCL,

ORDER

8. The Commission hereby directs the petitioner to submit an amended petition along

with their written argument within 10 days from the date of receipt of this order. On

receipt of the amended Petition and the written arguments, the Commission will

decide on the next course of action.

9. Let a copy of the order be served upon the petitioner (WBPDCL).

Sd/-

sd/-

sd/-

MEMBER

MEMBER

(PULAK KUMAR TEWARI) (DURGADAS GOSWAMI) (SUTIRTHA BHATTACHARYA)

CHAIRPERSON

DATE: 30.10.2021

Sd/-Secretary